



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	6912-1446:0100
CATEGORY:	6912 - VOICE COMMUNICATION ACCESSORIES
LISTEE:	EVAX SYSTEMS 20 McDermott Dr, Branford, CT, 06405 Contact: Lakomiak, Neil 13148661542 Email: neill@pottersignal.com
DESIGN:	Models EVAX 25, -25E, -50, -50E, -100, -100E, *-100M, -150, -150E, -200, -200E, *-200M, *-300, *-300E, *-400, *400E, *-500, *500E, *-600, *-600E, *EVX-SC, *EVX-RM module, *EVX-RM16 module, audio adjunct system. These units are intended to be used in conjunction with a listed electrically compatible fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	Input: 24-32 VAC/DC, Standby: 24 VDC, EVAX 25 / 25E / 50/ 50E 7-18 Ah Battery EVAX -100, -100E, *-100M, -150, -150E, -200, -200E, *-200M, *-300, *-300E, *-400, *400E, *-500, *500E, *-600, *-600E 7-24 Ah Battery
INSTALLATION:	In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as a voice/tone communication/evacuation/relocation/audio adjunct system for use with separately listed electrically compatible fire alarm speakers and control units. Supervision is dependent upon the fire alarm control panel. Refer to the control panel's listing and installation instructions for proper configurations. Suitable for high rise applications when used in conjunction with separately listed fire alarm control units. Refer to listee's Installation Instruction Manual for details.
NOTES:	

Revision
12/30/2019 JB



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/03/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division